

Town of Canton

Dog Park Electrical Scope of Work

DI:783867 Recreation Park Dog Park

The applicant will utilize contracts for the repairs to the site to restore this facility back "in-kind" to its pre-disaster design, function, and capacity within the existing footprint. **All electrical fixtures shall be installed above Flood Protection Elevation (FPE) of 2597.7 unless otherwise noted. Relocate all pedestal mounted fixtures behind the stage and the electric panel in the pavilion to west exterior wall of Stage above FPE. All switches and receptacles on the stage and in the pavilion that must be installed below Flood Protection Elevation for access must be routed through a common subpanel with a locking disconnect mounted above FPE.**

1. Pole adjacent to parking lot.
 - a. Remove 1 each of Standard 100A 120/240V Meter Base
2. Pedestal behind stage
 - a. Remove and Replace 1 each of Standard 100A 120/240V Meter Base
 - b. Remove and Replace 1 each of Siemens 12 circuit 120/240V- 100 Amp Main Breaker panel with 20/1 breakers
 - c. Remove and Replace 2 each of Siemens 100 Amp Main Breakers
 - d. Remove and Replace 2 each of Siemens 30/1 Breakers
 - e. Remove and Replace 4 each of 20A GFCI Receptacles
 - f. Remove and Replace outlet box, cast, poke-thru fitting, duplex receptacle & blank plate, 15 amp
3. Stage
 - a. Remove and Replace 10 each of 20A GFCI Duplex Receptacles
 - b. Remove and Replace 2 each of Light Switches
 - c. Remove and Replace 2 each of GFCI 20A 120V Outlets
4. Pavilion
 - a. Remove and Replace 1 each of 120/240V Single phase 20 circuit N1 Siemens Panel
 - b. Remove and Replace 2 each of 100 Amp Siemens Main Breakers
 - c. Remove and Replace 4 each of 20/1 Siemens Breakers
 - d. Remove and Replace 4 each of GFCI 20A 120V Outlets
5. Provide pressure treated stairs, railing and platform on west exterior wall of stage for access to the relocated electrical fixtures.
6. Provide signed and sealed as-built elevations and Elevation Certificate for all electrical panels, boxes, etc.